

Spacing Guide

Emergency Light

Remote Heads



2555 Leger Street, LaSalle, QC H8N 2V9, Canada
#4-801 30th Street NE, Calgary, AB T2A 5L7, Canada
Toll Free: (888) 992-7264 | arani.ca

Calculation Method

Based on a 100-ft-long, 3-ft-wide corridor
 Surface reflectances: ceiling 80%; walls 50%; floor 20%
 Calculation plane: 0 in
 Maintenance factor: 0.95




This document is provided for guidance purposes only and is to be considered a recommendation.

For official calculations and compliance with applicable codes and standards, the client must consult a qualified engineering firm.

Installation Height 8 ft

Ordering Code	Height	Tilt	Avg Ftc
EM1-2-14W-V1	8 ft	55°	1.04
EM1-2-4W-V1	8 ft	48°	1.03
EM2-2-4W-V2	8 ft	40°	1.03


Distance between remote heads



Installation Height 10 ft

Ordering Code	Height	Tilt	Avg Ftc
EM1-2-14W-V1	10 ft	45°	1.18
EM1-2-4W-V1	10 ft	28°	1.07
EM2-2-4W-V2	10 ft	30°	1


Distance between remote heads



Installation Height 15 ft

Ordering Code	Height	Tilt	Avg Ftc
EM1-2-14W-V1	15 ft	35°	1.05
EM1-2-4W-V1	15 ft	23°	1.03
EM2-2-4W-V2	15 ft	12°	1

Distance between remote heads



Installation Height 20 ft

Ordering Code	Height	Tilt	Avg Ftc
EM1-2-14W-V1	20 ft	20°	1.04
EM1-2-4W-V1	20 ft	10°	1.08
EM2-2-4W-V2	20 ft	5°	1.11

Distance between remote heads

